

Chris Austin

From: Josh Lipsky <JLipsky@rehabbuilders.com>
Sent: Friday, September 01, 2017 11:02 AM
To: rentalhelp
Subject: 2018 QAP Appendix B

NCHFA Team-

In reference to the proposed changes to the QAP:

2018 QAP appendix B. III. C.14- There are times where historic adaptive reuse projects or flat roof new projects will require dryer exhaust venting to the roof in order to install venting below the code maximum length for venting. Please consider changing language to allow venting to the roof on historic or new construction projects with flat roofs.

Thanks for your consideration,

Josh Lipsky
Rehab Builders, Inc.
770.318.9967